

UOJZ.S35608 - CONTROL UNITS, SYSTEM

Control Units, System

See General Information for Control Units, System

HONEYWELL INTERNATIONAL INC

S35608

12 Clintonville Rd
Northford, CT 06472-1610 USA

UL 864 9th Edition Listed

Model	Control Unit System Type(s)	Initiating Device Type(s)	Signaling Type(s)
H-S81-HS	L	A, M, SS, WF	C, March, NC
S81-HS/C	L	A, M, SS, WF	March, NC

UL 864 9th Edition Listed

Subassembly, Model(s) *S81-F3002-1, S81-F4001-1, S81-F4002-1, S81-F4003-1, S81-F5001-1, S81-F5002-1, S81-F5003-1, S81-F5004-1, S81-F6001-1, S81-F7001-1, S81-F7006-1, S81-F7011-1, S81-F7012-1, S81-F7013-1, S81-T8004-1, S81-T8007-2, S81-T9001-1, S81-T9002-1, S81-T9003-1, S81-T9004-1, S81-T9005-1*

L - Local System

A - Automatic Fire Alarm: thermostats, smoke detectors, etc.

M - Manual Fire Alarm: manually operated boxes

SS - Supervisory: gate valves, water-level switches, temperature switches, carbon monoxide alarm, residential fire alarm control units, etc.

WF - Waterflow Alarm: waterflow switches

C - Coded

March - March Time

NC - Noncoded, Steady, Temporal 3 Pattern, etc.

Last Updated on 2019-01-03

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"