

Technical Statement

Assessment of Compliance to ATEX 94/9/EC european directive

SCAME SISTEMI Srl

Via Lombardia, 5
I – 20010 Arluno (MI)

Statement : TÜV Rheinland Italia herewith declares that the below mentioned product, manufactured by "Scame Sistemi Srl", has to be considered Out of the scope of ATEX 94/9/EC European Directive.

Product : Description : **Fire & Gas Central Unit**
type : **S81 – HS (Including I/O modules)**

Assessment : Concerning the assessment, the content of Article 1.1 and 1.2 of ATEX Directive and the content of ATEX Guidelines (second edition) updated August 2008 § 3.10, have been considered. The common interpretation of the a.m. topics is that the control units shall be designed for the sole and specific use and goal "to provide executive actions on one or a small number of equipment..."

Another common example of application, with reference to the same article of ATEX Directive, is a complete Fire & Gas system, including sensors and final elements.

For the aforementioned reasons, the opinion of TÜV Rheinland Italia is that the Fire & Gas Central Unit S81-HS (including I/O modules), found compliant to IEC/EN 61508-1/7 and EN 50402, has to be considered Out of the scope of ATEX 94/9/EC European Directive.

Milan, July 24th 2009



Dipl.-Ing. J. Moreno

A handwritten signature in blue ink, appearing to read "J. Moreno".

TÜV Rheinland Italia – Industrie Service
Energy Systems & Automation Division
Via Italia, 1
I – 24030 Medolago (BG)
Tel. +39 035 4933147, e-mail: bergamo@it.tuv.com